



SRC Engineers, Inc



**UL 711 Testing Certificate
for
Burner Fire Control, Inc.**

This document certifies that Burner Fire Control, 280 Industrial Pkwy, Lafayette, LA. has successfully tested their 30 Gallon Compressed Air Foam System (CAFS) per UL 711(2009) for the following rating:

UL and UL Canada 20A: 120B

The testing was conducted by the Louisiana State University Fire and Emergency Training Institute (FETI) at their test facility located in Baton Rouge, LA. All testing was witnessed and certified by both LSU FETI officials and Stephen R. Callegari, SR., Professional Engineer, of SRC Engineers, Inc.

The 20A:120B tests shall be valid with Chemguard Class "A" foam, or any UL listed Class B foam. The testing of UL 120B shall be valid only with a UL listed Class "B" foam.

Stephen R. Callegari, SR., P.E.